



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

Nadukattu Esakkiammankoil Street, Near Alexon Hospital,

Palpannai, Nagercoil - 629 001

Phone: 04652 - 238315

E-mail: jwalabngl@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Test Report No:	TR/2026/53254	Report Issue Date :	19.08.2026	Page No.01 of 02
Invoice Details:	11507/Dt.11.08.2026/ Rs.1,652/			

Customer Name & Address	: Sri Gurugana Sambanthar Mission,
Contact No / Email.ID	Gardencourt Cambridge School,
	Kattadithattu,
	South Soorankudy Post.
Sample Name	: Drinking Water
Sample Description	: R O water
Sample Submitted by	: Sri Gurugana Sambanthar Mission
Location & Date	: Kattadithattu
Quantity of sample Received	: 2 Litres
Sample Container	: Jerry Cane
Sample Condition on Receipt	: Good
Sample Received On	: 11.08.2026
Test Commenced on	: 11.08.2026
Test Completed on	: 13.08.2026
Environmental Condition	: 24.5° C

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500:2012(RA:2019)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH	IS 3025 Part 11-2022	-	7.66	6.5-8.5	6.5-8.5
2	Total Hardness as CaCO ₃	IS 3025 Part 21-2009 (RA 2019)	mg/L	8	200	600
3	Total Alkalinity	IS 3025-Part 23-2023	mg/L	12	200	600
4	Chloride as Cl	IS 3025-Part 32-1988 (RA 2019)	mg/L	11	250	1000
5	Sulphate as SO ₄	IS 3025-Part 24-2022(Turbidity Method)	mg/L	<5	200	400
6	Nitrate as NO ₃	APHA 24 th Edition 2023 - 4500 -NO3 B	mg/L	<2	45	45
7	Fluoride as F	APHA 24 th Edition 2023 - 4500- F-D	mg/L	0.2	1.0	1.5

Remarks: The tested sample confirmed to IS: 10500:2012 (RA 2019) Drinking water Acceptable limit specification with respect to above tested parameters.

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. The test items will not be retained for more than 15 days from the date of issue of the test report.
4. The Result apply to the sample as Received.

Gardencourt Cambridge School

Authorized Signature

C. Nehru

PRINCIPAL

Gardencourt Cambridge School

Kattadithattu, Dharmapuram Village North

District: Kanyakumari

Junior Water Analyst, TWAD Board
DWTL, Nagercoil

Issue No./Date	01/01.10.2021	Amend. No/ Date	02.01.2024	Page No	1 of 1
----------------	---------------	-----------------	------------	---------	--------



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

Nadukattu Esakkiammankoil Street, Near Alexon Hospital,

Palpannai, Nagercoil – 629 001

Phone: 04652 - 238315

E-mail: jwalabngl@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Test Report No: TR/2026/53254-53255	Report Issue Date : 19.08.2026
Invoice Details: 11507/Dt.11.08.2026	

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500:2012(RA:2019)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
I.	PHYSICAL EXAMINATION					
8	Appearance	Physical observation	—	Clear	-	-
9	Colour	APHA 23rd Edition 2017 4500 H+B	Hazen	Colourless	Agreeable	Agreeable
II	CHEMICAL EXAMINATION					
10	Odour	IS 3025 Part 5 : 1983	—	None	-	-
11	Turbidity	APHA 23rd Edition 2017 - 2130 B	NTU	<0.5	1	5
12	Total Dissolved Solids	APHA 23rd Edition 2017 – 2540 C	mg/L	40	500	2000
13	Conductivity	APHA 23rd Edition 2017 – 2510 B	µS/cm	60	-	-
14	P – Alkalinity	IS 3025–Part 23-1983	mg/L	-	-	-
15	Calcium	APHA 23rd Edition 2017 – 3500 Ca B	mg/L	4	75	200
16	Magnesium	APHA 23rd Edition 2017– 3500 Mg B	mg/L	<2	30	100
17	Iron	APHA 23rd Edition 2017– 3500 Fe B	mg/L	0.24	0.3	1
18	Manganese	APHA 23rd Edition 2017 – 3500 Mn B	mg/L	0	0.1	0.3
19	Ammonia	APHA 17th Edition-1989– 4500 NH3C	mg/L	<0.05	0.5	0.5
20	Nitrite as NO ₂	APHA 23rd Edition 2017– 4500-NO2 B	mg/L	0.01	-	-
21	Total Phosphate as PO ₄	APHA 23rd Edition 2017 – 4500 P- D	mg/L	0.10	-	-
22	Turbidity	APHA 23rd Edition 2017 – 4500 O – B	mg/L	0.26	-	-
23	Residual Chlorine as RC	IS / APHA	mg/L	0.0	0.2	0.2
	BACTERIOLOGICAL EXAMINATION					
24	Faecal Coliform	IS / APHA	CFU / 100 ml	0	0	0

Remarks: The above water sample is chemically potable and bacteriologically safe.

Gardencourt Cambridge School

Note: **Authorised Signature**

1. The test results relate only to the items tested.

2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.

3. The test items will not be retained for more than 15 days from the date of issue of the test report.

4. The Result apply to the sample as Received.

PRINCIPAL

Gardencourt Cambridge School

Kattadithattu, Dharmapattinam Village North

Signature: Kanyasulkamari

Junior Water Analyst, TWAD Board
DWTL, Nagercoil

Issue No./Date	01/01.10.2021	Amend. No/ Date	02.01.2024	Page No	2 of 1
----------------	---------------	-----------------	------------	---------	--------



GOVERNMENT OF TAMIL NADU

DIRECTORATE OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

பொது சுகாதாரம் மற்றும் நோய்த் தடுப்பு மருந்துத்துறை

SELF DECLARED SANITATION CERTIFICATE

(Issued under G.O.(Ms)No. 276 of Health and Family Welfare (AB2) Department dated

23.09.2024 on the basis of affidavit by the applicant)

Certificate Number : TN00126KKM32641

Issued Date : 17-04-2026

Organization Type : Educational Institutions

Expiry Date : 16-04-2027

Name of the Organization : SRIGURUGNANASAMBANTHAR

MISSION GARDENCOURT CAMBRIDGE SCHOOL

Address : KATTADITHATTU, DHARMAPURAM NORTH,

PUTHENTHURAI POST, KANYAKUMARI DIST


I, VETRIVEL owner/manager of the SRIGURUGNANASAMBANTHAR MISSION GARDENCOURT CAMBRIDGE SCHOOL functioning as Educational Institutions located at Dharmapuram North in Kanniyakumari district hereby declare that

- This Self-Declared Sanitation certificate is valid from 17-04-2026 to 16-04-2027 and will be renewed every year prior to the expiry of the current certificate with updated information.
- Our premises can accommodate 1000 people/pupils and has 75 urinals and 33 toilets which is proportionate to the number of users as per government norms.
- 10 Sanitation workers are deployed to clean the entire premises including Toilets, Common Area Spaces, etc., at regular intervals and proper record is maintained.
- The waste generated on our premises is properly processed and disposed of as per Solid Waste management Rules, 2016.
- There is no potential mosquito breeding area on the premises.
- The premises have adequate drinking water fountains on each floor of the premises.
- The self-declared certificate is displayed prominently on the premises along with the protocol

The Government reserves the right to inspect at any point of time and cause for rectification or cancel or suspend the certificate and take legal action if any conditions are violated.

P. Dimple
Gardencourt Cambridge School

C. Nehru



Authorised Signature

PRINCIPAL

Signature of the Owner/Manager
Gardencourt Cambridge School



(அ) TN00126KKM32641 என்ற தனிப்பட்ட சான்றிதழ் எண்ணை
<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/> ல் உள்ளிடு செய்து சரிபார்க்கவும்.

(அல்லது)

(ஆ) கைப்பேசியில் பार्சுகொடு படிப்பான் மூலம் இணையதளத்தில் சரிபார்க்கவும்.

Genuineness of the certificate can be verified by.

(a) Keying in the unique certificate number TN00126KKM32641 in the URL

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/>

(or)

(b) Reading the 2D barcode with mobile barcode reader and verify through online.